



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/11/2025

Shift: B

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-16	Reported tripped	OLR acted.Reset done	15:00:00	15:10:00	
2	OHP	BF-7A	Reported red	E-stop operated.Released and tested okay	15:20:00	15:40:00	
3	OHP	CO-50	Reported tripped	OLR acted.Reset done	19:55:00	20:05:00	
4	CHP	Cc-28	Reported tripped	OLR acted.Reset done	17:00:00	17:10:00	
5	CHP	Cc 112 S-3	LT not moving and slew not taking place	Potentimeter in zero.Adjusted and tested okay.Slew wrong complaint	15:19:00	15:36:00	
6	CHP	CC 38 SCR-6	Lt not working	Lt drive tripped.Reset done(2 times)	15:24:00	17:58:00	
7	CHP	Cc-33 SCR-5	Lt not working	Drive tripped.Reset done	15:40:00	16:00:00	
8	CHP	CC 112 S-3	Reported no power	ACB tripped.Made on	16:10:00	16:50:00	
9	CHP	Cc 40 SCR-2	Reported Signal missing	Interlock ZSS cage not rotating due to belt problem.LT done and tested okay	18:37:00	19:14:00	
10	CHP	Cc-38 SCR-6	Reported LT drive tripping	Drive tripping on DC over current fault.Accleration and deceleration time increased and tested okay	19:30:00	20:00:00	
11	CHP	CC-40 SCr-2	LT not working	PCRD OT acted.Released and tested okay	20:21:00	21:25:00	
12	CHP	Cc-132	Reported tripped	OLR acted.Reset done(3 times)	14:35:00	17:03:00	
13	CHP	CR-1A,2A	Reported permissive not coming	fault reset done for lubrication oil flow and tested okay(2times)	14:50:00	20:55:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 29/11/2025

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	WT	AF-6	Reported tripping	Checked and found mechanical problem	18:45:00	18:55:00	Informed to mechanical
15	IOSA	OC-7A	Reported tripping	Checked and found motor running but gearbox not rotating.	19:00:00	19:30:00	Informed to mechanical