



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 02/09/2025

Area: CHP

Equipment	Job
LBDS 1	4 nos tube fixtures replaced
LC 17	Rooms cleaning done
SCR 8	LUFF pump contactor replaced
CC 38	TUL modification done
S1,S3	Stacking restriction angle limits tested
CC 38,104,SCR 6,9,CC 116,117,117TT	PPM was done
CC 38,39,40,41,43,47,50,SCR 3,6,7	Running inspection was done