



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 07/10/2025

Incharge(s): MAHENDRA SOLANKI

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO22	LEFT B/C NOT RUNNING, ZSS STONE STUCK	MADE FREE	06:45:00	06:55:00	
2	OHP	CO10A	OLR ACTED	RESET	07:50:00	08:00:00	
3	OHP	BRC ON CO32	B/C CHUTE JAMMED	INFORMED OPRATION	09:45:00	10:00:00	
4	OHP	BRC ON CO28	INTERLOCK ZSS ROD MISSING	MADE OK	11:00:00	11:15:00	
5	OHP	OHP and CHP STACKING STREAM	NO COMPLAINT	OK	06:00:00	14:00:00	
6	CHP	CC54	O/L	RESET	12:35:00	12:50:00	
7	CHP	CC51 MPD	TRIP	RESET	12:15:00	12:30:00	
8	CHP	CC36 SCR1	LUFF LIMIT ACTED	RELESED	09:30:00	09:40:00	
9	CHP	CC105 SCR10	B/C SIGNAL PROBLEM, ZSS CAGE STUCK	MADE FREE	11:45:00	12:00:00	
10	WT	OP10	D1 TRIP	BYPASS IN SCADA	11:30:00	11:40:00	
11	WT	EOT	CRANE NOT MOVING, REMOTE CELL DISCHARGE	NEW CELL REPLACED	08:45:00	09:00:00	
12	IOSA	OLD WOBR	B/C SIGNAL MISSING DUE TO ZSS CAGE STUCK	REPLACED WITH NEW CAGE	13:15:00	13:30:00	