



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/12/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TT1	LT not working,OLr acted	reset	22:50:00	22:59:00	
2	OHP	WOBR on CO 6A	bc not running,jamming	informed operation	23:30:00	23:45:00	
3	OHP	BRC on co 31	b/w 2 olr acted	reset	00:30:00	00:45:00	
4	OHP	CO 77	olr acted	reset	01:30:00	01:45:00	
5	OHP	BRC on Co 8A	bw1 and bw2 not running,stone stucked	informed operation	22:30:00	22:40:00	
6	OHP	CO 84	olr acted	reset	03:15:00	03:25:00	
7	OHP	BRC on co 8A	b/w 1 not running,oil level low	informed mechanical	04:30:00	04:40:00	
8	OHP	CC 38 SCR6	LT not working,drive tripped in f7404	reset	04:10:00	04:20:00	
9	CHP	CC 51	MPD tripped	reset	05:16:00	05:32:00	2 times
10	CHP	CC 54	olr acted	reset	05:16:00	05:20:00	
11	CHP	CC 40 SCR2	b/c not running,olr atced	reset	23:50:00	00:00:00	
12	CHP	CC 105 scr 10	luffing not taking place,wrong complaint,already boom touched pile	informed operator	03:30:00	03:40:00	
13	CHP	CC 48	zss acted,due to stone stucked in cage	new cage replaced	04:30:00	04:55:00	