



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/10/2025

Shift: B

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-25	Reported tripped	OLR acted.Reset done	17:40:00	17:50:00	
2	OHP	CO-29	Reported tripped	OLR acted.Reset done	18:10:00	18:15:00	
3	OHP	CO-6A	Reported BRS not getting reset	Sensors cleaned and tested okay	17:30:00	17:40:00	
4	OHP	RSCO-10A(C/D)	Reported tripped	OLR acted due to track jamming.Reset done(4times)	14:50:00 21:30:00	15:20:00 21:45:00	
5	OHP	CO-58(B/D)	Reported tripped	OLr acted.Reset done	14:55:00	15:00:00	
6	OHP	WOBR on CO-26	Slew not working	Drive tripped.Reset done	20:50:00	21:05:00	
7	OHP	TT-2 on CO-7A	Position indication not coming	Wire cut at sensor.Rejoint done	21:10:00	21:30:00	
8	OHP	BRC on CO-28	Reported B/C not running	Emergency stop at cabin side contact problem.Bypassed at PB.	21:00:00	21:20:00	
9	OHP	TBS on Co-7A	Reported right luff up not working	limit released and tested okay	21:40:00	22:00:00	
10	CHP	Cc-54	Reported tripped	OLR acted.Reset done(3 times)	17:20:00	17:25:00	
11	CHP	Cc-51A	Stopping on ZSS	Stone stuck in cage.Removed and tested okay	18:10:00	18:20:00	
12	CHP	CC-38 SCR-6	LT not working	M1 tripped due to track jamming.Reset done	15:10:00	15:25:00	Informed to operation
13	CHP	Cc-35 SCR-3	Luff not working	Limit acted.Released and tested okay	15:20:00	15:40:00	
14	CHP	Cc-223,222	Drive not healthy	Breaker tripped in Lc-5.Made on and ccr plc recycled.	15:30:00	16:30:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/10/2025

Shift: B

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	CHP	CC-112 scr-8	Signal missing for reclaiming	Bit bypassed in i/O rack and zss cage put down	19:30:00	20:15:00	
16	WT	OC-1A(B/D)	Reported tripped	OLR acted.Reset done	19:30:00	19:40:00	
17	IOSA	BRC	Reported Yard interlock signal missing	ZSS cage stone stuck up.Removed and given clearance	14:30:00 20:00:00 20:50:00	14:50:00 20:10:00 20:55:00	No delay