



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 24/06/2025

Area: WT

Equipment	Job
OP 6	after rake maintenance done, all drives de clutched and checked
OP 3	after rake maintenance done, D4 motor TB found fallen,removed and made it direct termination
CP 2 and 4	after rake maintenance done