



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 07/02/2026

Incharge(s): Lal Singh,Lal Singh

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29 WBR	LUFF EMERGENCY ACTED	RELEASED	14:35:00	14:45:00	
2	OHP	CO-2A	MIDDLE BELT SWAY SWITCH PROBLEM	SWITCH BYPASSED ( NO DELAY)	16:15:00	17:00:00	
3	OHP	CO-28 BRC	YARD ZSS INTRLOCK PROB PROBLEM	REPLACED	15:00:00	15:20:00	
4	OHP	CO-29	TRIPPED ON OLR	RESET DONE	18:00:00	18:10:00	
5	OHP	CO-12 CD	TRIPPED ON OLR	RESET DONE	18:30:00	18:40:00	
6	CHP	CC-33 S-3	BC TRIPPED ON OLR	RESET DONE	14:20:00	14:30:00	
7	CHP	CC-26	EMERGENCY PUSH BUTTON STUCK	MADE FREE	17:20:00	17:30:00	
8	CHP	CC-51	TRIPPED ON OLR 5 TIMES	RESET DONE	14:55:00	18:30:00	
9	CHP	CC-131	TRIPPED ON OLR 3 TIMES	RESET DONE	18:10:00	18:30:00	
10	WT	OT-4	D1 TRIPPED ON PGF-1 FAULT	RESET DONE	16:40:00	16:45:00	