



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 10/01/2026

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 11A	zss acted, probe damaged	probe replaced	19:25:00	19:50:00	
2	OHP	BRC on CO 28	LT problem, wrong complaint	LT taking place but operator not feel the LT as per operator by sitting idle in operator cabin	17:55:00	18:05:00	
3	OHP	TBS on CO 20	Luff not taking place, luff limit acted	mechanical doing work till 5.45 pm told to not operate machine, luff limit released	17:20:00	17:50:00	
4	OHP	wobr on co6A	b/c not running, BSS acted	informed mech	15:30:00	15:40:00	
5	OHP	BRC on CO 28	CT not working, drive tripped	reset	19:30:00	19:45:00	
6	OHP	wobr on CO 26	bw not running, olr acted	reset	16:30:00	16:45:00	
7	CHP	CC 51	mpd tripped 7 times	reset	15:50:00	15:55:00	
8	CHP	CC 114	motor tripped on olr	reset	18:20:00	18:25:00	
9	CHP	RG 2	stopped in zss, probe damaged	replaced	17:50:00	18:00:00	
10	CHP	CC 47	olr acted	reset	17:45:00	17:50:00	
11	CHP	CC 40 SCR2	signal missing	Lt done than ok	18:00:00	18:10:00	
12	WT	OT 2	d2 tripped 3 times in pgf1 fault	reset	17:45:00	17:50:00	
13	WT	OT 1	d1 tripped 3 times in pgf1 fault	reset	18:10:00	18:15:00	