



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 14/05/2025

Area: WT

Equipment	Job
OP 9	Trolley line side bushes /creepers cutting done @col no 80 and 65
EOT (O)	Aux hoist hook got stuck ,released it and reverse contactor replaced
CP 3	panel and motor side ppm done
OP 3	panel and motor side ppm done
OP 1,4 and 5	after rake maintenance done