



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 17/09/2025

Area: CHP

Equipment	Job
CC-114	panel and motor ppm done
Misc	mechanical BRS preparation is in progress
CC-44,105,108,125,SCR-10	Running inspection done
CC-31,32,36,39,40,SCR-4,5,3,1,STK-1	field devices inspection done for defects
CC-209,210,211,212,216,JH-17,18,19	dist panel blowing and tightness done.LDB panel blowing and tightness done
CC-40,STK-1,CC-201,202,203	ppm done