



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/10/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on CO 25	no power,pcrd cable divided in two piece from pendulum switch	isolator checked,all fuse ok,megger done	00:40:00	01:40:00	DNW will come in A shift
2	OHP	CR 1	tripped in Over current	reset	05:15:00	05:25:00	
3	OHP	CO 77	OLr acted	reset	23:00:00	23:10:00	
4	OHP	CO 30 BRC	LT not working,OT acted	OT released	00:02:00	00:15:00	
5	OHP	TBS on CO 21	LT not working,control is in off from control desk	made it on	05:00:00	05:15:00	
6	OHP	TBS on CO 21	luffing not working,full jamming	informed operation	05:35:00	05:45:00	
7	CHP	CC 201,203	OLR acted	reset	22:50:00	22:59:00	
8	CHP	CC 31 SCr 4	light not glowing,light having fault	rectified	23:50:00	00:05:00	
9	CHP	CC 31 SCR4	BW not running,BW stucked ,after giving cmd b/w immediately stop	electrical side all ok,informed operation	00:05:00	00:35:00	
10	CHP	CC 37 SCR7	LT not taking place,OT acted	OT released	01:00:00	01:10:00	
11	CHP	CC 40 SCr3	luffing down limit bypass	again kept in ckt	02:40:00	02:50:00	
12	CHP	CC 40 SCR3	LT not taking place,MPCB tripped,track jammed	made it on,informed operation for cleaning	02:55:00	03:05:00	
13	CHP	CC 203 ,	FG 29 signal missing	panel side given high in new LC C1	04:00:00	04:15:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/10/2025

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 38 SCR6	LT MPCB 6 tripped	made it on	04:08:00	04:25:00	
15	CHP	CC 36 SCR 1	BW olr acted	reset	04:50:00	05:00:00	
16	CHP	CC 28	motor tripped in OLR,current value 700 A	informed operation ,they are not agreed and tell to give in local	03:20:00	03:50:00	5 times olr acted
17	CHP	CC 131	olr acted	reset	04:00:00	04:05:00	2 times
18	WT	CP1	no movement,emergency acted in pusher	informed operation,emergency released	23:30:00	23:45:00	operation delay