



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/05/2025

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on CO 20	left B/C not running, OLR acted	reset	09:30:00	09:45:00	
2	OHP	CO25	OLR acted	reset	07:00:00 07:50:00	07:10:00 07:58:00	
3	OHP	CO 29	OLR acted	reset it done	08:00:00	08:10:00	
4	OHP	CO 35	OLR acted	reset	09:00:00	09:10:00	
5	CHP	CC 32 SCR 5	LT not working,drive trips in overload due to track jamming	reset it done and inform operation	07:01:00	07:15:00	
6	CHP	CC 32	not running,olr acted	reset it done	07:30:00	07:40:00	
7	CHP	CC107	olr acted	reset it done	10:00:00	10:10:00	
8	CHP	CC 125	OLR acted	reset it done	11:35:00	11:40:00	
9	CHP	CC 35 SCR 2	LT reverse not taking place,reverse contactor NO contact problem	NO contact wire connected to spare NO contact	11:07:00	11:30:00	
10	CHP	CC 105 scr 10	luffing down not taking place, luff down solenoid stucked up	solenoid manually pressed than ok	07:55:00	08:10:00	