



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 02/05/2025

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO43 A	chute sensor acted,module problem, instrumentation problem	chute sensor bypass	18:30:00	18:45:00	informed operation
2	OHP	TBS 24	LT not taking place,M4 tripped in olr	reset it done	15:40:00	15:55:00	
3	OHP	TT1 on co 7a	cable opened in elemex connector	tightened it	17:00:00	17:15:00	
4	OHP	BRC 31	b/c olr acted	reset it done	20:00:00	20:10:00	
5	OHP	CO 61	OLr acted	reset it done	15:40:00	15:50:00	
6	OHP	CO 33M	olr acted	reset it done	17:00:00	17:10:00	
7	OHP	CO 8a BRC	LT not taking place,ACB is in off	made it on	21:15:00	21:30:00	
8	CHP	CC 33 SCR4	LT not working,M3 trip due to track jamming	olr reset,informed operation for cleaning	20:10:00	20:20:00	
9	CHP	CC 44	MPD trip	made it on	20:00:00	20:10:00	
10	CHP	CC 32 scr 5	LT not taking place,Ot acted	released	19:45:00	20:00:00	
11	CHP	CC 54	tripped in OLR	reset it done	17:50:00	17:55:00	
12	CHP	CC 114	trips in OLR	reset it done	20:35:00	20:40:00	
13	IOSA	OC2A,OC 7A	conveyor stops due to incomer 1 tripped in UV fault in HVMCC5 of 1-142LC1	fault reset done, bus coupler made on	19:35:00	19:50:00	