



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 12/02/2026

Area: OHP

Equipment	Job
co-16, tt-3	motor and panel side ppm is done. co-16 spare core for mechanical brs from field to io is traced, to be connected. takeup area lighting isolator is replced.
1-141lc-7 io rack	io rack one sitop is sourced with 110v from om-12.
co-31a	take up area lighting is improved.
co-34a	realignment is done due to high vibrations,
co-38a,38b; co-2a,rsco-10a	motor and panel side ppm is done.
wbr-2 on co-25	brake supply is restored and regulation is done.
IO-11	ht isolator ppm is done, earthing mechanism rectified.
co-11a gallery	lighting and plug sockets wiring dressing is done.
cr-2a zss	probe replaced, as older probe has failed.
vf-23	m1 and m2 power cable from local panel is replaced.
rsco-1a spare 22kw	trail run taken,
brc-4 on co-28 ; tbs-5 on co-24, co-24	motor and panel side ppm is done. pcrd guide rollers issue observed, informed mechanical. tbs-5 lighting is improved.
vf-1a and vf-2a	speed references have been checked and set, found ok.
CO-3A	mechanical brs spare bit (i105.6) at 1-141lc4 io rack is programmed and indication provided in HMI.