



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 01/08/2025

Area: IOSA

Equipment	Job
1-142LC-3	DNW HAS COME TO CHECK INCOMER-1, AS IT HAS TRIPPED YESTERDAY ON E-FAULT. FOUND FLASH IN CUBICLE. PRESENTLY LOAD IS ON INCOMER-2 AND BUSCOUPLER IN PCC.
WOBR-FLS	DAMAGED and UN-USED LUBRICATION PANEL REMOVED FROM BOOM CONVEYOR AREA.
OC-6A	PPM DONE ON MOTOR AND FIELD DEVICES.