



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 20/01/2026

Area: OHP

Equipment	Job
crusher -1 and 2 panels	outgoing cable entry point is closed using glass putty.
co-41a hoist	mpcb is fixed in place of thermal olr.
12a t/e ; 11a gallery lubrication pump area of locp-2	lighting is improved.
jh o-3	ldb, pdb and hoist panel blowing is done.
tt-1 pcrd cable	inspection is done
co-2a, 58,rsco-9a,,rsco-10a	running inspection is done.
wbr-3 on co-29	shifted to co-26
wbr-1 on co-26	shifted to repair bay
1-14lc4 bus coupler voltas breaker	maintenance is done .