



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 06/12/2025

Area: OHP

| Equipment | Job |
|---|--|
| wbr-1,2,3 | bucket wheel motor inspection is done. |
| co-29 ; wbr on co-29 | ppm is done |
| brc-3 on co-34 ; co-19 | ppm is done. co-19 motor ppm is done |
| rco-1a h/e ; 36b gallery ; 35a gallery areas | lighting is improved |
| ground hopper | hoist ppm is done, lighting timer is replaced and restored lighting circuit. |
| 1-141lc4 to 1-14lc6 | profibus cable laid between vf-22 level to lc6 and restored redundant plc communication. |
| co-13 belt and carriage ; co-15 ,tt-2; co-8a ; db-1 | motor and feeder side ppm is done. |