वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 01/09/2025 Shift: B

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO-28	REPORTED B/C NOT RUNNING CHECKED AND FOUND E/STOP ACTED	E/STOP RELEASED THEN OK	17:40:00	17:50:00	
2	OHP	CO-87	OLR ACTED	OLR RESET	18:20:00	18:30:00	
3	OHP	CO-111	REPORTED RED OLR ACTED	OLR RESET DONE	19:30:00	19:40:00	
4	OHP	TBS ON CO-19	LBC STOPPING ON ZSS	CHECKED AND FOUND PROBE PROBLEM.BYPASSED AT MODULE TO MINIMIZE DELAY	17:00:00	17:40:00	PROBE TO BE REPLACED
5	CHP	CC-39 SCR-7	PCRD DRUM CHAIN CUT (OLD PROBLEM)	AFTER MECHANICAL WORK COMPLETE THAN MOTOR CONNECTION GIVEN AND PCRD CABLE PROPERLY WINDING DONE THEN LT TRIAL RUN TAKEN OK	14:20:00	14:40:00	
6	CHP	CC112 SCR-8	REPORTED LUFFING NOT WORKING CHECKED AND FOUND NO PROBLEM	FAULT RESET IN OPERATOR CABIN THEN OK	14:40:00	14:50:00	
7	CHP	CC-31 SCR-4	LT NOT TAKING PLACE	TRACK JAMMING FOUND	14:50:00	15:00:00	INFORMED TO OPERATION
8	CHP	CC105 SCR-10	REPORTED B/C HEALTHY STOP	CHECKED AND FOUND UPPER HOUSE I/O RACK SIDE CPU MCB FAILED. MCB REPLACED WITH NEW THEN OK	17:50:00	18:10:00	
9	CHP	CC-34 SCR-2	REPORTED SLEW NOT TAKING PLACE CHECKED AND FOUND 30 DEGREE LIMIT ACTED	RESET AND SLEW TRIAL RUN TAKEN OK	15:00:00	15:10:00	NO ELECTRICAL PROBLEM OPERATOR FAULT

वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 01/09/2025 Shift: B

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
10	CHP	CC28 TT	CHUTE SENSOR ACTED	CHECKED FOUND CABLE OLD JOINT FAILED. PROPER JOINT DONE THEN OK	15:40:00	16:00:00	
11	CHP	CC-54	REPORTED TRIPPED	OLR ACTED.RESET DONE	16:50:00 17:00:00	16:55:00 17:05:00	
12	CHP	CC 105 SCR 10	REPORTED SIGNAL MISSING	LT FORWARD DONE AND TESTED OKAY	19:50:00	20:10:00	
13	WT	OT-3	DRIVE TRIP (2TIMES) DUE TO ENCODER FAULT	DRIVE RESET DONE	19:20:00 20:50:00	19:25:00 20:55:00	
14	IOSA	TBS ON OC-13A	RBC STOPPING ON ZSS	CHECKED AND FOUND MATERIAL STUCK. MADE FREE AND TESTED OKAY	15:55:00	16:15:00	