



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 09/08/2025

Incharge(s): Lal Singh

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|---|---|----------------------|----------------------|---------|
| 1 | OHP | CO-18 FG | FLAP GATE TRIPPED | MADE ON | 09:30:00 | 09:40:00 | |
| 2 | OHP | CO-26 WOBR | SLEW DRIVE TRIPPED | RESET DONE | 11:00:00 | 11:15:00 | |
| 3 | OHP | BRC ON CO -31 | BC STOPPING BECAUSE OF CHUTE SENSOR MALFUNCTION | CHUTE SENSOR BYPASSED | 11:00:00 | 11:30:00 | |
| 4 | OHP | CO-67 | TRIPPED ON OLR | RESET DONE | 06:10:00 | 06:15:00 | |
| 5 | OHP | CO-10A | TRIPPED ON OLR | RESET DONE | 06:15:00 | 06:30:00 | |
| 6 | OHP | CO-87 | TRIPPED ON OLR | RESET DONE | 09:15:00 09:40:00 | 09:20:00 09:45:00 | |
| 7 | CHP | cc-51 | TRIPPED ON OL | RESET DONE | 07:40:00 08:15:00 | 07:45:00 08:20:00 | |
| 8 | CHP | CC-29 FG | FLAP GATE TRIPPED | RESET DONE | 07:25:00 | 07:30:00 | |
| 9 | CHP | CC-105 SCR-7 | LT M2 AND M3 TRIPPED | RESET DONE ... PCRD DRUM ARRESTED DUE TO MECH PROBLEM | 07:45:00 | 08:00:00 | |
| 10 | CHP | CC-44 | TRIPPED ON OLR | RESET DONE | 12:40:00 | 12:55:00 | |
| 11 | CHP | CC-39 | TRIPPED ON OLR | RESET DONE | 13:50:00 | 14:00:00 | |
| 12 | CHP | CC-38 SCR-6 | BC STOPPING | CHECKED FOUND OK ... TESTED | 13:15:00 | 13:35:00 | |
| 13 | WT | OT-4 | D-2 TRIPPED ON PGF-4 FAULT | RESET DONE | 11:25:00 | 11:30:00 | |
| 14 | WT | EOT- ORE | MCCB TRIPPED | MADE ON AND TESTED | 11:00:00 | 11:05:00 | |