



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 02/12/2025

Area: WT

Equipment	Job
MIS	30 KW (AF) motor recived from E R S and fixed the Fan
MIS	Dai of Encoder shaft reduced to suitable size for fixing, 2 nos
MIS	space heater supply provided @ LC 2A for T2
OP 1,5 and 8	After rake,maintenance done
CP 1 and 4	After rake,maintenance done