



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 29/04/2025

Area: IOSA

Equipment	Job
OC-23A	FILED DEVICES CABLE TRAY GOT RUSTED AND BROKEN. CABLE DRESSING DONE AFTER CABLE TRAY WELDING.
MISC	BASE FRAME FABRICATION IS IN PROGRESS FOR UPS SYSTEM
UPS	BATTERIES TOP UP DONE , LINKS CONNECTED AND VOLTAGES CHECKED.