



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 21/05/2025

Area: WT

Equipment	Job
LC 1	All drive panels and I/O panel blowing room cleaning done
OP 5	Bottom C -clamp found damaged ,replaced it and trolley line checked up to col no 60 from 80 ,OK
OP 2,3,4,5,6 and 7	after rake maintenance done