



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 29/01/2026

Incharge(s): Nagendra Midde

Shift: A

| Sl No | Area | Equipment | Problem                | Action | From                 | To                   | Remarks |
|-------|------|-----------|------------------------|--------|----------------------|----------------------|---------|
| 1     | OHP  | VS1A      | OLR ACTED              | RESET  | 07:50:00             | 08:00:00             |         |
| 2     | CHP  | CC 114    | OLR ACTED              | RESET  | 08:10:00             | 08:15:00             |         |
| 3     | CHP  | CC 51     | FEEDING CONV OLR ACTED | RESET  | 10:45:00             | 13:30:00             | 6 TIMES |
| 4     | CHP  | CC 54     | OLR ACTED              | RESET  | 12:45:00             | 12:50:00             |         |
| 5     | WT   | AF5       | DRIVE TRIPPED          | RESET  | 11:55:00<br>13:00:00 | 12:00:00<br>13:05:00 |         |
| 6     | WT   | OP6       | DRIVE 5 OLR ACTED      | RESET  | 11:50:00             | 12:05:00             |         |