



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 20/11/2025

Area: IOSA

Equipment	Job
OC-13A	BELTSWAY ( RR) FEEDBACK IS CONTINUOUSLY HIGH . FOUND INDUCTION VOLTAGE OF 63V IS COMING. RECTIFICATION IS IN PROGRESS.
OC-15A	BRS MODULE FIXED AND CONNECTIONS GIVEN. FEEDBACK CHECKED AND KEPT IN LINE.
OC-18A	PULL CHORD HARDWARE SIGNAL NOT COMING. RECTIFIED THE DEFECTIVE PULL CHORD SWITCH , REMOVED BYPASS AND FEEDBACK CHECKED.
OC-7B	CONVEYOR GALLERY LIGHTING CIRCUIT DEFECTS RECTIFICATION IS IN PROGRESS. LIGHTING IMPROVED.
BLENDER RECLAIMER	PPM DONE ON MOTORS