



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 27/12/2025

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 29,45,46,44	showing red,in programming h/w 3 of DI card showing faulty	control mcb of i/o rack made off and on than ok	14:50:00	15:10:00	
2	OHP	BRC on Co 8A	BW 2 not running stone stucked up in B/W2	remove stone clearance given	18:08:00	18:20:00	
3	OHP	WOBR on co 26	slew not working,drive tripped	reset	20:40:00	20:50:00	
4	CHP	CC 37 SCR7	slew not working,oil cooling motor tripped,one phase wire got cut under slew chamber	temporary 3 core supply given to fan motor	18:25:00	19:00:00	
5	CHP	CC 51	MPD tripped 6 times	reset	15:50:00	20:20:00	
6	CHP	cc 131	olr acted 4 times	reset	16:43:00	19:35:00	
7	WT	OT 1	D1 tripped in PGF1 fault	reset	21:10:00	21:15:00	