



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 07/11/2025

Area: WT

| Equipment | Job |
|--------------------|---|
| MIS | RMD room near railway building,supply checked,found cable joint open(digging to be done) |
| OP 7 | Panel and Motor side ppm done |
| OP 2,3 ,7 and CP 1 | After rake maintenance done |
| CP 4 | Trolley line inspection done,found no complaints |
| CT complex | Lighting timer circuit checked found cable joint melted and got open ,rectified it |
| MIS | Damaged C-clamps collected from pushers ,20 nos for repair |