



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 28/12/2025

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 34	OLR ACTED	RESET	01:10:00 04:30:00	01:15:00 04:35:00	
2	OHP	SCR 6 ON CC 39	LT DRIVE TRIPPED	RESET	02:05:00 05:00:00	02:20:00 05:10:00	
3	OHP	VF 23	M1 TRIPPED	RESET	01:40:00	01:50:00	
4	CHP	CC 117	OLR ACTED	RESET	22:30:00	05:00:00	5 TIMES
5	CHP	CC 58	OLR ACTED	RESET	22:50:00	23:05:00	
6	CHP	CC 55	OLR ACTED	RESET	00:05:00	00:10:00	
7	CHP	CC 51A	OLR ACTED	RESET	03:00:00	03:10:00	
8	CHP	CC 131	OLR ACTED	RESET	01:30:00	01:40:00	
9	CHP	CC 52	FEEDING CONV MPD ACTED	RESET	02:40:00	02:50:00	
10	CHP	CC 130 ZSS	BELT SLIPPING	INFORMED TO OPRN	02:00:00	02:10:00	
11	CHP	SCR 3 ON CC33 LT	PCRB POWER MCCB WAS IN OFF CONDITION	MADE IT ON	03:20:00	03:30:00	
12	CHP	CC 125	OLR ACTED	RESET	03:40:00	03:45:00	
13	CHP	CC 39	OLR ACTED	RESET	05:55:00	06:00:00	
14	IOSA	OC 7B	MOTOR PROTECTION RELAY REPLACED	CHECKED AND GIVEN CLEARENCE	22:00:00	23:30:00	