



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/02/2026

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CR 3A	crusher permissive not coming,solenoid switch problem	switch replaced	15:45:00	16:35:00	
2	OHP	CO 26	olr acted	reset	20:00:00	20:10:00	
3	OHP	CO 34	olr acted	reset	21:30:00	21:40:00	
4	CHP	CC 102 TT on CC106	signal not coming	given high in I/O rack	15:00:00	15:15:00	
5	CHP	CC 58	OLR acted	reset	15:10:00	15:20:00	
6	CHP	CC 51	MPD acted	reset	21:20:00	21:25:00	
7	CHP	cc 54	OLR acted	reset	18:25:00	18:30:00	
8	CHP	CC 31	olr atced	reser	18:05:00	18:10:00	
9	CHP	CC 106	ZSS acted,ZSS module problem	module replaced	16:05:00	16:15:00	
10	CHP	CC 216	Olir acted	reset	16:45:00	16:50:00	
11	CHP	CC 104 SCR7	LT not working,PCRD OT acted	OT released	17:30:00	17:35:00	
12	CHP	CC 40 SCR2	ZSS probe damaged	PROBE replaced	17:45:00	17:55:00	
13	CHP	CM18	all conveyor red,no power,,ACB tripped in LC 18	made it on	18:00:00 18:30:00	18:10:00 18:40:00	