



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 23/09/2025

Shift: B

Incharge(s): Amit Roy,K SANKARA RAO

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|---|--|----------------------|----------------------|---------|
| 1 | OHP | CO-10A | OLR ACTED | RESET DONE | 15:00:00 | 15:20:00 | |
| 2 | OHP | BRC ON CO-28 | REPORTED B/W-1,B/W-2 NOT RUNNING CHECKED AND FOUND BOTH POWER MCCB OFF CONDITION | B/W-1 AND B/W-2 POWER MCCB MADE ON | 20:00:00 | 20:30:00 | |
| 3 | OHP | CO-9 | OLR ACTED | RESET DONE | 21:25:00 22:00:00 | 21:35:00 22:05:00 | |
| 4 | OHP | WOBR ON CO-25 | INTERLOCK ZSS CAGE STUCK UP WITH STONE | STONE REMOVED THAN OK | 21:30:00 | 21:45:00 | |
| 5 | CHP | CC-54 | OLR ACTED | RESET DONE | 17:15:00 | 17:20:00 | |
| 6 | CHP | CC-117 | OLR ACTED | RESET DONE | 20:35:00 | 20:40:00 | |
| 7 | CHP | CC-51 | OLR ACTED (4TIMES) DUE TO FEEDING CONVEYOR STOP | RESET DONE | 19:30:00 | 21:00:00 | |
| 8 | CHP | CC-38 | REPORTED C/S NOT HEALTHY CHECKED AND FOUND COAL MATERIAL JAMMING | SENSOR CLEAN THAN OK | 15:20:00 | 15:30:00 | |
| 9 | CHP | CC-37 SCR-7 | REPORTED SLEW NOT WORKING CHECKED SPIDER ALARM FILTER P2 FULL THAN INFORMED TO MECHANICAL | FILTER POSITION CHANGE THAN SPIDER RESET SLEW PUMP ON THAN SLEW OK | 19:20:00 | 19:50:00 | |