



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/11/2025

Shift: B

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on CO-6A	B/C stopping on ZSS	ZSS probe damaged.Replaced	15:30:00	15:50:00	
2	OHP	CO-13	Reported Tripped	OLR acted.Reset done	17:10:00	17:20:00	
3	OHP	CO-37A	Reported healthy stop	Contactar arc chute problem.Rectified	15:15:00	15:35:00	
4	OHP	BRC on CO-30	B/C stopping	OLR acted(6 times).Reset done	17:50:00	19:00:00	
5	OHP	CO-85	Reported tripped	OLR acted.Reset done	18:25:00	19:45:00	
6	OHP	CO-16	BRS not healthy	Fuse blown in C.Jb.Replaced	18:30:00	18:40:00	
7	OHP	CO-29	Reported tripped	OLR acted.Reset done	20:10:00	20:20:00	
8	OHP	RSCO-10A(C/D)	MPCB tripped	Reset done	16:35:00	16:45:00	
9	CHP	CC-51	MPD tripped	REset done	15:40:00	15:45:00	
10	CHP	CC-52	Reported tripped	OLR acted.Reset done	21:54:00	21:58:00	
11	CHP	CC105 scr 10	SLEW and B/W not working	E pb acted.Released and tested okay	17:20:00	17:35:00	
12	CHP	CC014 SCR-9	Reported slewing not working	OIL level low.	19:02:00	20:30:00	Informed to mechanical
13	CHP	CC-32 R-1	Luffing down not working	Oil level low. air locked	20:48:00	21:26:00	Informed to mechanical
14	CHP	CC39 SCR-1	B/c not working	cage made down and given for reclaiming.Rectified in program and removed ZSS	21:30:00	21:40:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/11/2025

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	CHP	CC-125	OLR acted	Reset done	20:30:00	20:35:00	
16	CHP	CC-45	OLR acted	Reset done(3 times)	16:00:00	17:20:00	
17	CHP	CC-38 SCR-6	Reported LT not working	Drive tripped.Reset done	20:12:00	20:25:00	
18	CHP	CC-28 position on CC-31	Sensor problem	Bypassed	14:10:00	14:20:00	
19	WT	OT-1	Drive 1 tripped on PGEF fault	Reset done	20:30:00	20:35:00	
20	WT	OT-3	DRive 1 tripped on encoder fault	REset done	21:40:00	21:45:00	
21	IOSA	OC-21A	Reported ZSS acting	ZSS cage stuck up with stone	20:00:00	20:15:00	