



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 17/01/2026

Area: WT

Equipment	Job
OP 2	All Motors meggering and control checking done 1AT,2AT,3AT timers time adjusted (12,7,6 sec)
CP 4	Top power collector set replaced and Trolley Line inspection and top bus bar alignment done @73 and 33
OP 6	Section isolaters maintenance done 3 nos ( Line completed)
OP 1,5,6 and 8	After rake maintenance done
CP 1 and 4	After rake maintenance done
MIS	LC 10B room cleaning done