



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 18/06/2025

Area: OHP

Equipment	Job
co-7	schneider mpr is installed and ctmf protection relay is removed.
co-5 pullchord	pullchord cable from slope area to tailend 110m is changed and checked.
brc on co8a	pcrd cable layering is checked and panel side tightness checked.
brc on co-32	b/w zss spare cores identified and restored in circuit.
tbs on co-20	ppm is done