



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 11/02/2026

Area: IOSA

Equipment	Job
CHUTE VIBRATOR	CHUTE VIBRATOR MOTOR BASE MADE READY FOR OC-23A TO OC-25A CHUTE. WILL BE FIXED TOMORROW
OM-4	RESISTORS REPLACED IN OM-4 RIO NODES.
OM-1	RESISTORS REPLACED IN OM-1 RIO NODES
HOUSEKEEPING	DONE AT 1-142LC2 FIRST FLOOR
ELECTRICAL HOISTS	PPM DONE ON PANEL AND MOTORS OF ELECTRICAL HOISTS AT OC-5A, 7C, 21A,23A,27A CONVEYORS HEADEND.
OC-36A	PPM DONE ON MOTOR AND FIELD DEVICES.