



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 24/05/2025

Area: IOSA

| Equipment | Job |
|------------------|--|
| OC-16A | PULL CHORD HARDWARE DEFECT CHECKING IN PROGRESS. |
| COMPRESSOR HOUSE | HOIST PPM DONE |
| OJH-11A | HOIST PPM DONE. |
| OC-17A | ZONE-1 RIGHT PULL CHORD COVERING DONE. |
| OC-3A | ZERO SPEED CAGE GOT DAMAGED. REPLACED WITH SPARE |