



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/05/2025

Incharge(s): K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 35	OLR ACTED	RESET	01:30:00	01:40:00	
2	OHP	CO 26	OLR ACTED	RESET	03:00:00	03:10:00	
3	OHP	TBS ON CO 20	LT NOT TAKING PLACE PCRD O/T ACTED	RELEASED	02:00:00	02:15:00	
4	OHP	CO 11 (C) DRIVE	MPCB TRIPPED	MADE ON	05:00:00	05:10:00	
5	OHP	CO 32	ZS PROBE DAMAGED	PROBE REPLACED	03:00:00	03:15:00	DUO TO BELT JUMPING IN FORMED TO MECH
6	CHP	CC 107	BRS ACTED	SENSORS CLEANED THAN OK	01:20:00	01:30:00	
7	WT	OP 5	D5 OLR ACTED	RESET	00:40:00	00:50:00	