



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 15/12/2025

Shift: B

Incharge(s): Saurabh Kumar Yadav

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------------------|-------------------------------|--------|----------------------------------|----------------------------------|---------|
| 1 | OHP | CO 29 | OLR ACTED | RESET | 15:00:00 18:30:00 20:25:00 | 15:10:00 18:40:00 20:35:00 | |
| 2 | OHP | CO 26 | OLR ACTED | RESET | 20:50:00 | 21:00:00 | |
| 3 | CHP | CC 51 | FEEDING CONV OLR ACTED | RSEST | 18:50:00 | 20:25:00 | 4 TIMES |
| 4 | CHP | CC 54 | OLR ACTED | RESET | 15:35:00 | 15:40:00 | |
| 5 | CHP | SCR 9 ON CC 104 SLEW | SPIDER BREAK FAIL ALARM ACTED | RESET | 16:30:00 | 16:40:00 | |
| 6 | CHP | CC 108 | OLR ACTED | RESET | 20:25:00 | 20:30:00 | |
| 7 | WT | OT3 | DRIVE1 TRIPPED | RESET | 17:15:00 17:30:00 | 17:20:00 17:35:00 | |