



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 26/11/2025

Area: CHP

Equipment	Job
CC-131, TT on CC-131	conveyor motor ppm done. TT LT motor and panel ppm done
TT ON CC-117	TT LT mtor, flap gate motor and panel ppm done
CC-213	Drive end chute sensor and control supply on healthiness included in HMI display and tested ok
SCR-5	LT motor no-2 changed and tested ok
SCR-8 lighting	circuit rectification done and sufficient lighting provided
CC-31	motor ppm done
SCR-4	motors ppm done
SCR-4	HT cable sleeve done by DNW. support given for the work