



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 29/04/2025

Area: CHP

Equipment	Job
CC 27 T/T	Old power cable joint done properly and Power charged
CC 27 , CC 27A	panel side and motor side PPM done
CC 51	4 No s BS Switches Installed and wired
	HT and LT powers normalized after DNW work
S2	New Slew Induction motors installed, Power and control wiring done and trail run taken in local mode.

LC 17 & LC 18 T1