



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 12/01/2026

Incharge(s): K SANKARA RAO

Shift: A

| Sl No | Area | Equipment     | Problem  | Action   | From                             | To                               | Remarks                  |
|-------|------|---------------|--|--|----------------------------------|----------------------------------|--------------------------|
| 1     | OHP  | TBS ON CO-20  | R/ LUFF NOT WORKING OLR ACTED                            | RESET DONE   | 12:30:00                         | 12:40:00                         |                          |
| 2     | OHP  | CO-67         | TRIPPED ON OLR   | RESET DONE   | 07:10:00                         | 07:20:00                         |                          |
| 3     | OHP  | VS-2A         | OLR ACTED  | RESET DONE   | 07:50:00                         | 08:00:00                         |                          |
| 4     | OHP  | CO-50         | TRIPPED ON OLR   | RESET DONE   | 09:00:00                         | 09:10:00                         |                          |
| 5     | OHP  | BRC ON CO-28  | REPORTED B/W-1 NOT RUNNING FOUND GUIDE ROLLER FELL DOWN  | INFORMED TO MECHANICAL                                 | 10:30:00                         | 10:40:00                         |                          |
| 6     | OHP  | BRC ON CO-28  | B/W-2 NOT RUNNING CHAIN FELL DOWN                        | INFORMED TO MECHANICAL                                 | 07:00:00                         | 07:10:00                         |                          |
| 7     | OHP  | WOBR ON CO-26 | REPORTED LT NOT TAKING PLACE FOUND PCRD GEAR BOX PROBLEM | PCRD CABLE PROPER LAYING WAS DONE AND INFORMED TO MECH | 08:30:00                         | 08:50:00                         |                          |
| 8     | OHP  | CO-12         | REPORTED STOPPING ON ZSS CAGE STUCK UP WITH STONE        | REMOVED THAN OK  | 11:15:00                         | 11:25:00                         |                          |
| 9     | OHP  | CO-12         | STOPPING ON ZSS  | ZSS BYPASSED   | 13:00:00                         | 13:10:00                         | TO BE CHECKED IN B SHIFT |
| 10    | OHP  | CC-40 SCR-2   | B/C OLR ACTED  | RESET DONE   | 08:00:00                         | 08:10:00                         |                          |
| 11    | CHP  | CC-117        | TRIPPED ON OLR (3TIMES)                                  | RESET DONE   | 07:00:00<br>08:35:00<br>12:45:00 | 07:05:00<br>08:40:00<br>12:50:00 |                          |
| 12    | CHP  | CC-58         | TRIPPED ON OLR (2TIMES)                                  | RESET DONE   | 08:50:00<br>09:10:00             | 08:55:00<br>09:15:00             |                          |



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 12/01/2026

Incharge(s): K SANKARA RAO

Shift: A

| Sl No | Area | Equipment       | Problem   | Action                               | From     | To       | Remarks |
|-------|------|-----------------|---|--------------------------------------|----------|----------|---------|
| 13    | CHP  | CC-131          | TRIPPED ON OLR                                      | RESET DONE                           | 13:10:00 | 13:15:00 |         |
| 14    | CHP  | CC-54           | TRIPPED ON OLR (3TIMES)                             | RESET DONE                           | 11:50:00 | 12:20:00 |         |
| 15    | CHP  | CC-51           | OLR ACTED (3TIMES)                                  | RESET DONE                           | 11:00:00 | 11:30:00 |         |
| 16    | CHP  | CC-51           | MPD TRIP (5TIMES) FEEDING CONVEYOR STOP             | RESET DONE                           | 06:50:00 | 13:30:00 |         |
| 17    | CHP  | CC-39<br>SCR-6  | LT NOT TAKING PLACE DRIVE TRIP 7404 FAULT           | RESET DONE                           | 07:50:00 | 08:00:00 |         |
| 18    | CHP  | CC-112<br>SCR-8 | SLEW PUMP NOT RUNNING                               | PLC POWER RECYCLED THAN OK           | 08:20:00 | 08:50:00 |         |
| 19    | CHP  | CC-39<br>SCR-6  | LT NOT TAKING PLACE DRIVE FAULT 30002               | DRIVE RESET DONE                     | 09:00:00 | 13:30:00 |         |
| 20    | CHP  | CC-125          | STOPPING ON ZSS DUE BELT SLOW                       | INFORMED TO MECH                     | 10:00:00 | 10:10:00 |         |
| 21    | CHP  | CC-34<br>SCR-1  | LT NOT TAKING PLACE DRIVE TRIP DUE TO TRACK JAMMING | RESET DONE AND INFORMED TO OPERATION | 13:30:00 | 13:40:00 |         |
| 22    | WT   | OT-1            | DRIVE -1 PGF-1 FAULT TRIP                           | RESET DONE                           | 09:30:00 | 09:35:00 |         |