



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 10/05/2025

Area: IOSA

Equipment	Job
MISC	1 NO HT PANEL WHICH ARE REMOVED FROM MACHINE SHIFTED FROM OUTSIDE OF SHED TO INSIDE.
TBS	ISOLATED CABLES 4 NOS REMOVED
OJH-5A	ELECTRICAL HOIST POWER MADE ON AND CHECKED ALL FUNCTIONS.
OC-31A	MOTOR AND FIELD PPM DONE
OC-15A	ZSS CAGE AND MODULE CHECKING DONE. CJD AND ZSS FEEDBACK CHECKED.
WOBR(L and T)	CHECKED ALL SLEW AND FIELD DEVICES.
WOBR(FLS)	TRIAL RUN TAKEN AFTER ADJUSTING SLEW - YARD INTERLOCK PROXIMITY SWITCH.