



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/06/2025

Shift: A

Incharge(s): Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO 28	BC not running due to emergency stop acted	released	08:00:00	08:15:00	
2	OHP	RSCO 10A	Carriage drive MPCB tripped	MADE ON	10:45:00	10:55:00	
3	OHP	CR 1	Not healthy , contact coil burn	Refer to gen shift	10:20:00	10:40:00	
4	OHP	CO 61	BRS bypass request by operation	bypassed at CJB	12:20:00	12:30:00	
5	OHP	CO 29	OLR acted	reset done	06:20:00 13:50:00	06:25:00 14:00:00	
6	OHP	VS 1A	OLR acted	reset done	06:25:00	06:30:00	
7	OHP	CO 27A	OLR acted	reset done	07:40:00	07:50:00	
8	OHP	BRC on CO 34	CT not running (2 times)	Drive tripped on overload , reset done	08:30:00	08:55:00	
9	OHP	CO 26	OLR acted	reset done	13:25:00	13:35:00	
10	OHP	BRC on CO 30	BC Chute sensor not healthy	Chute sensor bypassed and informed to operation	13:30:00	13:45:00	Informed to B shift for checking
11	OHP	VS 4A	Hoist not working due to MPCB tripped	made on	11:30:00	11:45:00	
12	CHP	CC 114	OLR acted	reset done	13:10:00	13:20:00	
13	CHP	CC 39 , SCR 7	Slew return filter problem , was bypassed in C shift	Mechanical work done, bypass removed	06:30:00	07:10:00	
14	CHP	CC 125	OLR acted	reset done	13:40:00	13:50:00	
15	CHP	CC 31	OLR acted	reset done	07:20:00 11:00:00	07:30:00 11:15:00	



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 27/06/2025

Incharge(s): Arnab Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	CHP	CC 31 , S -1	BC not running	OLR acted , reset done	10:20:00	10:35:00	
17	CHP	CC 34 , SCR 2	Luffing not working	Mechanical filter problem , informed	10:20:00	10:35:00	
18	CHP	CC 32 , SCR 5	LT not working	M-2 , M-3 tripped , reset done	10:30:00	10:45:00	
19	CHP	CC 104 , SCR 9	BC signal missing	Rec mode bypass removed in CM 18	10:45:00	11:20:00	
20	CHP	CC 31	BRS bypass request from operation, acting due to dust	Bypassed	06:45:00	06:47:00	in system