



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 28/10/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

| Sl No | Area | Equipment     | Problem  | Action                             | From     | To       | Remarks             |
|-------|------|---------------|--|------------------------------------|----------|----------|---------------------|
| 1     | OHP  | CO 58         | mpcb tripped due to overload                                     | made it on                         | 07:25:00 | 07:30:00 |                     |
| 2     | OHP  | TBS on Co 7A  | luff not taking place,olr acted                                  | reset                              | 07:10:00 | 07:25:00 |                     |
| 3     | OHP  | TBS on Co 21  | Lt not taking place,M4 mpcb tripped                              | made it on                         | 09:37:00 | 09:50:00 |                     |
| 4     | OHP  | BRC on Co 8A  | b/c not running,MCCB tripped ,motor winding one phase got opened | motor changing going on by G shift | 09:40:00 | 10:00:00 |                     |
| 5     | OHP  | WOBR on Co 29 | LT not taking place,M3 overload due to track jamming             | reset                              | 11:30:00 | 11:40:00 |                     |
| 6     | OHP  | CO 67         | olr acted  | reset                              | 12:00:00 | 12:10:00 |                     |
| 7     | OHP  | CO 26         | olr acted  | reset                              | 12:42:00 | 12:50:00 |                     |
| 8     | OHP  | BRC on CO 32  | B/c not running,E pb acted near operator cabin                   | E PB released                      | 12:45:00 | 13:00:00 |                     |
| 9     | OHP  | RCO 1A        | ZSS acted,zss probe damaged                                      | probe replaced                     | 07:45:00 | 08:00:00 |                     |
| 10    | OHP  | TIS 1 on CO5  | not healthy,mpcb tripped ,v belt got cut                         | made it on                         | 11:00:00 | 11:10:00 | informed mechanical |
| 11    | CHP  | CC 104 SCR9   | slew not working,mpd tripped due to overload                     | reset                              | 07:25:00 | 07:35:00 |                     |
| 12    | CHP  | CC 33 SCR 5   | b/c not running,belt slipping                                    | informed mechanical                | 07:30:00 | 07:40:00 |                     |
| 13    | CHP  | cc 35 scr3    | b/c not running,belt slipping                                    | informed mech                      | 09:14:00 | 09:25:00 |                     |



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 28/10/2025

Incharge(s): Saurabh Kumar Yadav

Shift: A

| Sl No | Area | Equipment    | Problem  | Action                           | From     | To       | Remarks |
|-------|------|--------------|--|----------------------------------|----------|----------|---------|
| 14    | CHP  | CC 38 SCR6   | LT not working,M2 and M3 tripped due to jamming        | informed operation               | 10:10:00 | 10:20:00 |         |
| 15    | CHP  | CC 37 SCR7   | Lt not working, track jamming motor2,3 and 4 , tripped | reset                            | 11:10:00 | 11:20:00 |         |
| 16    | CHP  | C C 35 SCR 3 | b/ c not running,belt slipping                         | informed mechanical              | 11:15:00 | 11:30:00 |         |
| 17    | CHP  | CC 38 scr 6  | b/c not running,belt snapped                           | informed mechanical              | 13:00:00 | 13:10:00 |         |
| 18    | CHP  | CC 113 A     | olr acted  | reset                            | 13:15:00 | 13:20:00 |         |
| 19    | CHP  | LC 19        | I/C 1 tripped in E/F 51G due to LDB                    | reset ,isolated e/f ,made I/C on | 11:30:00 | 11:40:00 |         |
| 20    | WT   | OT1          | d1 tripped in pgf1 fault                               | reset                            | 06:30:00 | 06:35:00 |         |