



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 25/07/2025

Area: OHP

Equipment	Job
co-5,9,6 brs	brs kept in circuit on operation request
co-69	schneider MPR is installed in place of CTMF relay.