



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 14/02/2026

Incharge(s): Nagendra Midde

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------------|---------------------------|--------------------------------------|----------------------|----------------------|---------|
| 1 | OHP | CO 1A ZSS | ZSS PROBE CHECK NUT LOOSE | TIGHTENED | 18:40:00 | 18:55:00 | |
| 2 | OHP | WBR ON CO 29 LT | ACB IS IN OFF CONDITION | MADE IT ON | 14:50:00 | 15:00:00 | |
| 3 | OHP | CO 26 | OLR ACTED | RESET | 16:00:00 | 21:10:00 | 5 TIMES |
| 4 | OHP | CO 29 | PULL CORD BYPASSED | DUE TO CABLE CUT DURING JCB CLEANING | 16:20:00 | 16:30:00 | |
| 5 | OHP | BRC ON CO 31 LT | PCRD O/T ACTED | RESET | 17:00:00 | 17:10:00 | |
| 6 | CHP | CC 51 | FEEDING CONV OLR ACTED | RESET | 16:20:00 | 20:50:00 | |
| 7 | CHP | CC 58 | OLR ACTED | RESET | 21:25:00 | 21:40:00 | |
| 8 | CHP | SCR 1 ON CC 34 | POSITION SENSOR CHANGED | AND KEPT IN CIRCUIT | 14:30:00 | 14:50:00 | |
| 9 | CHP | CC 216 | OLR ACTED | RESET | 14:50:00 | 15:00:00 | |
| 10 | CHP | CC 108 | OLR ACTED | RESET | 16:20:00 17:30:00 | 16:30:00 17:40:00 | |