



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 10/12/2025

Area: OHP

Equipment	Job
TIS-2	motor meggered along with cable trail run taken, current is balanced (4A) and restored in circuit after trail run is complete.