



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/10/2025

Incharge(s): Lal Singh

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	TRIPPED ON OLR	RESET DONE	00:00:00	00:10:00	
2	OHP	CO-111	TRIPPED ON OLR	RESET DONE	22:25:00	22:35:00	
3	CHP	CC-28 TT ON CC31	POSITION INDICATION PROBLEM	BYPASSED IN IO RACK	00:05:00	00:10:00	
4	CHP	CC-51	MPD TRIPPED (12 TIMES FEEDING STOPPED)	RESET DONE	22:30:00	05:30:00	
5	CHP	CC-34 SCR-2	LT NOT WORKING ...PCRD OT ACTED	RELEASED	01:30:00 23:40:00	01:40:00 23:50:00	
6	CHP	CC-45	TRIPPED ON OLR	RESET DONE	00:25:00 01:35:00	00:35:00 01:42:00	
7	CHP	CC-32	TRIPPED ON OLR	RESET DONE	03:05:00	03:10:00	
8	CHP	CC-112 SCR-8	BC NOT RUNNING MPD TRIPPED OF EF	RESET DONE AND TESTED	04:25:00	04:35:00	