



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 07/06/2025

Area: WT

Equipment	Job
OP 8	Drive 1(M6) checked found motor mis alignment ( to be done)
CC 9 side	lighting problem rectified(cable loose in LDB)
OP 4	panel and motor side ppm done
OP 2	panel and motor side ppm done
OP2,4,7 and 10	after rake maintenance done