



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 23/08/2025

Area: CHP

Equipment	Job
SCR 4	Slew speed reduced on operation request
CC 37	Drive end chute sensor modification done
CC 37 HT coupler	Maintenance was done ,replaced fuses and charged supply
VF level	LDB problems rectified and improved lighting
R and C Lab	Power cable laying under progress
JH C19,C212	Hoist panels maintenance done
CC 108,VS2,VF2	PPM was done
S1,SCR 7,SCR 10	3 nos machine shiftings were done