



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 03/11/2025

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO-10A	Reported tripped	OLR acted.Reset done	17:45:00 18:05:00	18:00:00 18:10:00	
2	OHP	WOBR on CO-26	Reported slewing not taking place	Drive tripped. reset done	18:15:00	18:25:00	
3	OHP	CO-85	Reported Tripped	OLR acted.Reset done	21:15:00	21:20:00	
4	CHP	CC-54	reported tripped	OLR acted(20 times).Reset done	15:40:00	21:45:00	
5	CHP	CC-51A	Reported tripped	Tripped on rotor lock(2 times) due to jamming.Reset done	20:34:00	20:55:00	
6	CHP	CC-51	Stopping on ZSS	Due to pulley slip no belt movement found.	21:00:00	21:10:00	Informed to operation
7	CHP	CC-113A	Reported tripped	OLR acted.Reset done	21:18:00	21:28:00	
8	CHP	Cc34 SCR-2	Slew not working	30 degree limit acted.Right side slew done and tested okay	15:30:00	15:40:00	
9	CHP	Cc-33 scr-5	B/C ZSS problem	Sensor replaced and tested okay	15:00:00	15:30:00	
10	CHP	CC-105 scr-10	LT not working	PCRD cable fell down due to guide problem. guide adjustment done by mechanical and cable winding done and LT tested okay	16:40:00	17:00:00	
11	CHP	CC-37 SCR-7	B/C stopping	signal missing.Yard zss kept in line for reclaiming	16:55:00	17:15:00	
12	CHP	CC125	Reported tripped	OLR acted.Reset done	20:45:00	20:50:00	
13	CHP	Cc35 SCR-3	Luffing not working	UP command not coming to PLC.Spare core identified and connected and tested okay	21:40:00	22:00:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 03/11/2025

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	WT	OP-6	Reported not moving	Pusher at no power zone.Jumper laid and reverse movement done	21:15:00	21:20:00	
15	WT	OP-7,8	Reported no movement taking place	Checked and found modem and ethernet cable failed at OT-4.Modem replaced,configured and ethernet cable replaced and tested okay	20:30:00	22:00:00	