



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/06/2025

Shift: C

Incharge(s): V Balaji Naik, G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on CO6A	LT tripping frequently found M1 motor bearing struck up and olr acting	M1 motor power disconnected in terminal at panel	22:40:00	23:00:00	may further follow to normalize the system
2	OHP	CO11 carriage	Not moving found MPCB trip	Reset done	01:55:00	02:00:00	
3	OHP	BRC on CO32	BC ZSS acting found tail pulley ZSS targets damaged 2 no's and probe fixing clamp missing	ZSS bypassed at module informed operational incharge and operator	22:40:00	23:00:00	
4	OHP	BRC on CO8a	BC not running found OLR acted	Reset and made it on	00:40:00	01:00:00	
5	OHP	BRC on CO32	BC not running found BC drive olr acted due to belt jamming	Informed to operation for clearing jam	00:40:00	00:50:00	BC Belt cut
6	OHP	CO29	Reported red olr acted (5 times)	Reset done	23:08:00	23:15:00	0035am to 0045am: 01.28am to 01.38am : 02.00am to 02.10am: 03.15am to 03.30am
7	CHP	CO27A	Chute sensor acted due to chute jam	Informed to operation after clearance reset done	00:20:00	00:30:00	
8	CHP	CC28 TT on chute position on CC33	Glass fuse blown	Replaced then ok	04:14:00	04:25:00	



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 18/06/2025

Incharge(s): V Balaji Naik, G Eswara Rao

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
9	CHP	CC131	Motor tripped on over load 2 times	Reset done	02:30:00 23:05:00	02:35:00 23:10:00	
10	CHP	SCR9 on CC104	Slewing not working found panle MPR trip (earth fault)	Reset done	23:20:00	23:30:00	
11	CHP	SCR2 on CC34	Lt not working found PCRDT OT acted	Tesnion released then ok	02:45:00	02:55:00	
12	CHP	CC203 and CC201	Over load trip	Reset done	04:00:00	04:10:00	
13	WT	OP9	Communication problem	Modem and antena cleaned and ethernet cables reconnected then ok	00:00:00	01:30:00	